



Environmental

PH#: 941-747-4151

4455 18th St. East, Bradenton, FL 34203

barriers@aerflo.com

Oil-Only 20-Gallon Spill Kit # - Absorbs up to 15.2 Gallons

SPKO-20 Specifications

Dimensions:	ext. dia. 23" x 19.5" H
Shipping	23" W x 23" L x 19" H
Dimensions:	
Sold as:	1 per package
Absorbency:	Up to 15.2 gal. per package
Weight:	22.53 lbs.
# per Pallet:	16
Incinerable:	No
Ship Class:	175
Includes:	25 - 15" x 19" White Oil-Only HeavyWeight SonicBonded Pads (WPB100H) 4 - 3" x 4' White Oil-Only Sorbent Socks (WSO430) 2 - 18" x 18" White Oil-Only Sorbent Pillows (WPIL1818) 4 - 18" X 30" Yellow Disposal Bags & Ties (A-DISPAG) 1 - Pair Nitrile Gloves (A-GLV-NIT) 1 - Safety Goggles (A-GOG) 1 - 3" x 5" Vinyl Spill Kit Label (A- KITLABEL) 1 - 23" x 19" Yellow 20-Gallon OverPack (1H2/X75/S) (A20OVER) 6 - 6" x 2" TamperProof Seals (A- SEAL)



Metric Equivalent Specifications

Dimensions:	ext. dia. 58cm x 50cm H
Shipping	58cm W x 58cm L x 48cm H
Dimensions:	
Absorbency:	Up to 57.5 L per package
Weight:	10.2 kg

Regulations and Compliance:

49 CFR 173.3(c)(1) - If a container of hazardous waste is damaged or leaking, it can be placed in a compatible salvage drum that meets UN criteria for shipping

40 CFR 263.31 - Transporters, "must clean up any hazardous waste discharge that occurs during transportation...so that the hazardous waste discharge no longer presents a hazard to human health or the environment."

40 CFR 263.30(a) - In the event of a spill, transporters must, "take appropriate immediate action to protect human health and the environment."

33 CFR 154.1047(c)(2) - Concerning navigation and navigable waters, a facility which handles, stores or transports Group V petroleum oils must identify response plan resources such as containment booms and other methods.

29 CFR 1910.1450(e) - OSHA requires containment and cleanup materials for spills in laboratories to reduce occupational exposure to hazardous chemicals.

29 CFR 1910.120(j)(1) - Under an OSHA requirement, "DOT-specified salvage drums or containers and suitable quantities of proper absorbents shall be kept available and used in areas where spills, leaks, or ruptures may occur."